

**BEFORE THE GUJARAT ELECTRICITY REGULATORY COMMISSION
GANDHINAGAR**

Petition No. 2451 of 2025.

In the Matter of:

Petition to devise a mechanism to implement this Commission's Tariff Order No. 05 of 2024 dated 31.08.2024 by relaxing the requirement to install Remote Terminal Unit at each Wind Turbine Generator in the State of Gujarat.

Petitioner : Rajpur Renewables Pvt. Ltd.
1st Floor, Eastern Wind, Thapar House,
124, Janpath, New Delhi – 110 001.

Represented By : Ld. Adv. Mr. Raheel Patel and Adv. Yash Dadhich
V/s.

Respondent No. 1 : State Load Despatch Centre – Gujarat,
Sardar Patel Vidyut Bhavan,
Race Course Circle,
Vadodara – 390007, Gujarat.

Represented by : Ld. Adv. Ms. Ranjitha Ramchandran along with
Mr. Parag Parmar, Mr. Bhargav Mehta and
Mr. G.S. Aparnathi

Respondent No. 2 : Gujarat Urja Vikas Nigam Ltd.,
Sardar Patel Vidyut Bhavan,
Race Course Circle,
Vadodara – 390007, Gujarat.

Represented by : Ld. Adv. Ranjitha Ramchandran along with
Mr. Rahul Pareek

CORAM:

**Anil Mukim, Chairman
Mehul M. Gandhi, Member
S.R. Pandey, Member**

Date: 22/07/2025.

DAILY ORDER

1. The matter was kept for hearing on 28.05.2025.
2. Ld. Adv. appearing for the Petitioner submitted that the present Petition is filed by the Petitioner requesting the Commission to devise a mechanism to implement this Commission's Tariff Order No. 05 of 2024 dated 31.08.2024 by relaxing the requirement to install Remote Terminal Unit at each Wind Turbine Generator in the State of Gujarat.
 - 2.1. It is submitted that as per the Order dated 28.03.2025, the Commission had allowed the Petitioner to commission its 30 MW WTGs by providing the real time electrical and weather parameters of each WTGs to SLDC through SCADA gateway subject to final outcome of the Petition without creating any right including any equitable right in favour of the Petitioner and other parties. It is submitted that Petitioner has filed the affidavit dated 27.05.2025 and undertook that its OEM confirms about providing details of SCADA data on each WTG basis and pooling station created and utilized through communication from the year when it was introduced its accuracy and utilization.

2.2. Commission had in its earlier Order noted that after grant of interim relief to the Petitioner, several other project developers, including KP Energy, ACME Pokhran Ltd. and M/s Suzlon Global services Ltd. who are similarly commissioned wind projects used the Suzlon manufactured turbines, have approached the Commission seeking equivalent relief. After careful review of their respective submissions and technical similarities, and in adherence to the principle of Regulatory consistency and equitable treatment, the Commission extended identical interim relief to these developers. The five specified parameters are adequate for SLDC's operational requirement is the availability of the data (of five parameters) on real time basis from individual WTG Analog such as (a) MW, (b) MVAR, (c) Voltage (R-Y Phase), (d) Frequency and Digital (e) Circuit Breaker Status (Double time).

3. Ld. Adv. appearing on behalf of the Respondent SLDC submitted that the Petitioner has integrated LVRT, HVRT, Wind Speed and Wind Direction data at Pooling Station RTU through SCADA of individual WTG. The SOE Buffer Test through SCADA / RTU at individual WTGs is pending and the Petitioner has undertaken to do the same by 08.07.2025.

3.1. It is further submitted that said commissioning is on interim basis based on Order dated 28.03.2025 and is subject to the Final Order of the Commission. The requirement of Respondent SLDC is the availability of data i.e., the five parameters on real time basis from the individual WTGs.

4. Heard the parties. We note that pursuant to the Daily Order dated 28.03.2025, the Petitioner has vide its affidavit dated 27.05.2025 undertaken about its OEM confirms about providing details of SCADA data on each WTG basis and pooling station created and utilized through communication from the year when it was introduced its accuracy and utilization. Therefore, as the Petitioner has agreed to provide the details and the Respondent SLDC has also not raised any objections for the said details to be provided on real time basis.
5. The parties are directed to complete their pleadings within two weeks-time and file its written submissions, if any, within one weeks-time with a copy to other side.
6. The next date of hearing would be intimated separately.
7. We Order accordingly.

Sd/-
[S. R. Pandey]
Member

Sd/-
[Mehul M. Gandhi]
Member

Sd/-
[Anil Mukim]
Chairman

Place: Gandhinagar.
Date: 22/07/2025.